


## DESCRIPTION OF C6 / C6M CONTROLLER MODBUS

EN



This manual is compatible with C6 / C6M controller firmware version X.X.X.18 and above (X – does not matter).

C6 / C6M controller supports **Modbus RTU** and **Modbus TCP** protocols. Both protocols are using main commands to read and preset registers. Supported Modbus commands are presented in Table 1.



**When using Modbus RTU or Modbus TCP/IP, minimum polling time should be 500 ms or longer. In cases when multiple AHU's are connected to the same Modbus network, at least 1s. polling time is recommended.**

**Table 1. Supported Modbus commands**

Function code	Description
03	Read Holding Registers
06	Preset Single Register
16	Preset Multiple Registers


**Modbus RTU** protocol works via RS-485 interface. Default interface settings are presented in Table 2. Default interface settings and Modbus RTU protocol ID can be changed using the website. To change settings, connect air handling unit (AHU) to your network. Default AHU IP address is 192.168.0.60. Go to your browser and type default AHU IP address. You should see „Login“ window (Fig. 1). To login type username and password. Default username: „user“ and password: „user“.

**Table 2. Default settings of RS485 interface**

Baudrate	19200
Word length	8
Parity	EVEN
Stop bits	1

**Fig. 1. Website login window**

To find RS-485 interface settings and Modbus RTU protocol ID go to „SETTINGS“ and „CONNECTIVITY“ (Fig. 2). If you logged in, but can't open „SETTINGS“ window make sure, that JavaScript in your web browser is enabled (activated).




**Fig. 2. Connectivity settings**

If you can't see „Login“ window, make sure that:

- your device and air handling unit are connected in the same network;
- your device and air handling unit are in the same subnet;
- your proxy server and firewall isn't blocking connection;
- you typed correct IP address.


If your device is connected directly to C6 / C6M controller, make sure, that your DHCP server is disabled and your static IP is in same subnet. If you are using PC and Windows operating system, go to „Local Area Connection Properties“, go to „Internet Protocol Version 4 (TCP/IPv4) Properties“ (Fig. 3), check „Use the following IP address“ and type your static parameters, for example:

- IP address: 192.168.0.61;
- Subnet Mask: 255.255.255.0;
- Default gateway: 192.168.0.1.



**Fig. 3. Personal computer static IP address configuration**

The air handling unit has external connection terminals in the control box, inside the air handling unit. Modbus A and B communication wires can be connected to 1 and 2 terminals of connection for external elements (Fig. 4, Fig. 5, Fig. 6). To connect devices use twisted pair cable. Maximum cable length is 150 m. C6 / C6M controller ground point and ground point of another Modbus device should be connected together, if distance between the RS-485 interfaces is more than 10 m. (Fig. 4, Fig. 5, Fig. 6).



1. Ethernet connection of computer network or Internet
  2. Controller panel connection
  3. Connection of external elements

**Fig. 4. C6 and C6M controllers with the connection terminals**

RS485				TG1				DX				AUX				B1				B5				OUTPUTS				S1	
		A	B			GND				GND			GND			GND													
Override	—	NO	—	Kitchen hood	—	NO	—	Modbus RTU	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	N			
—	—	—	—	Kitchen hood	—	NO	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Fireplace	—	NO	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Fire alarm	—	NO	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Common	—	NC	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Common	—	C	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Supply air	—	0..10V	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	VAV sensor	—	GND	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Exhaust air	—	0..10V	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	VAV sensor	—	GND	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Air quality	—	0..10V	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	or humidity	—	GND	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	sensor 1	—	+24V	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Air quality	—	0..10V	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	or humidity	—	GND	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	sensor 2	—	+24V	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Air damper	—	Q	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	actuator	—	-230V	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
—	—	—	—	Max. load	—	15W	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
INPUTS				B6				B7				B8				B9				FG1				S1					

**Fig. 5. C6 connection diagram for external elements**

B6	Supply air VAV sensor	0..10V	22	1	NTC	Return water temperature sensor	BS
		GND	23	2	10k		
		+24V	24	3	NTC		
B7	Extract air VAV sensor	0..10V	25	4	10k	Supply air temperature sensor	B1
		GND	26	5	C		
		+24V	27	6	NO		
B8	Air quality or humidity sensor 1	0..10V	28	7	NC	Common Control Fire alarm Fireplace Kitchen Override	INPUTS
		GND	29	8	NO		
		+24V	30	9	NO		
B9	Air quality or humidity sensor 2	0..10V	31	10	NO	24V DC; 0..10V output	AUX
		GND	32	11	0..10V		
		+24V	33	12	GND		
OUTPUTS	Common	C	34	13	+24V	External DX unit	DX
	Heating	NO	35	14	+24V		
	Cooling	NO	36	15	0..10V		
	Alarm	NO	37	16	GND		
FG1	Air damper actuators Max. 15 W	Q	38	17	0..10V	Water mixing valve actuator	TC1
		-230V	39	18	GND		
		N	40	19	+24V		
S1	Water pump Max. 100 W	-230V	41	20	A	Modbus RTU	RS485
		N	42	21	B		

Fig. 6. C6M connection diagram for external elements

Modbus TCP protocol works via Ethernet interface, connection is provided to RJ-45 socket on the C6 / C6M controller (Fig. 4). Default IP address is 192.168.0.60, and port is 502. To connect C6 / C6M controller via Modbus TCP make sure, that proxy servers or firewall isn't blocking device destination IP address and 502 port is opened. Controller IP address can be changed using the website (Fig. 2). Instructions how to connect and login to website was presented at Modbus RTU section. IP address and subnet mask also can be changed using C6.1 touch panel. To find these settings click touch C6.1 panel screen, click „Menu“ button, click „Settings“ button and don't release it, for more than 5 seconds, after that „Advanced settings“ window will pop-up. Click „Connectivity“ button and here you will find IP address and subnet mask (Fig. 7). If you want to change one of these parameters, just click on it and edit.





Fig. 7. C6.1 touch panel connectivity settings

For connection the CAT5 category cable should be used. The maximum cable length between device and controller C6 / C6M is 100 m.

C6 / C6M controller Modbus registers with descriptions are presented in Table 3.



**Table 3**

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Main control	Modes	1	ON/OFF status	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		2	Auto mode control	RO	unsigned char	0 - 1	Scheduling = 0, Air Quality = 1	
		3	ECO mode	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		4	AUTO mode	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		5	Current mode	R/W	unsigned char	0 - 10	READ ONLY: Stanby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4, Kitchen = 5, Fireplace = 6, Override = 7, Holiday = 8, Air quality = 9, Off = 10 WRITE ONLY: Away = 1, Normal = 2, Intensive = 3, Boost = 4	
		6	Scheduler operation mode	R/W	unsigned char	0 - 3	StayAtHome = 0, WorkingWeek = 1, Office = 2, Custom = 3	
		7	Next mode	RO	unsigned char	0 - 8	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4, Kitchen = 5, Fireplace = 6, Override = 7, Holidays = 8	
		8	Next mode start time	RO	unsigned short	0 - 1439	Minutes	(0 - 1439 => 0:00 - 23:59); 130 => 2:10
		9	Next mode weekday	RO	unsigned char	0 - 7	Week days: None = 0, Mo = 1, Tu = 2, We = 3, Th = 4, Fr = 5, Sa = 6, Su = 7	
		10	Before been mode mask	RO	Unsigned char	0 - 31	Standby => 0, Away => 1 bit, Normal => 2 bit, Intensive => 3 bit, Boost => 4 bit	
Temperature and flow control	Temperature and flow control	11	Temperature control	R/W	unsigned char	0 - 3	Supply = 0, Extract = 1, Balance = 2, Room = 3	
		39	Room sensor	R/W	unsigned char	0 - 1	Panel temperature(1) = 0, Panel temperature(2) = 1	
		12	Flow control	R/W	unsigned char	0 - 2	CAV = 0, VAV = 1, DCV = 2, OFF = 3	
		13-14	Maximum supply flow	RO	unsigned int	0 - 200000	m3/h, l/s	
		15-16	Maximum extract flow	RO	unsigned int	0 - 200000	m3/h, l/s	
		17	Max supply pressure	R/W	unsigned short	0 - 1000	Pa	
		18	Max extract pressure	R/W	unsigned short	0 - 1000	Pa	

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Main control	Control sequence	19	Stage 1	R/W	unsigned char	0 - 3	None = 0, External coil = 1, Electric heater = 2, External Dx unit = 3 ,	
		20	Stage 2	R/W	unsigned char	0 - 3	None = 0, External coil = 1, Electric heater = 2, External Dx unit = 3 ,	
		21	Stage 3	R/W	unsigned char	0 - 3	None = 0, External coil = 1, Electric heater = 2, External Dx unit = 3 ,	
		22	Coil type	R/W	unsigned char	0 - 1	Hot water = 0, Cold water = 1, Combi = 2,	
		40	Icing protection	R/W	unsigned char	0 - 2	Off = 0, On = 1, External coil = 2	Only for plate heat exchanger
		41	Indoor humidity	R/W	unsigned char	-1; 10 - 90	Auto = -1, Manual = 10-90%RH	Only for plate heat exchanger
Main control	Connectivity	35	DHCP On/Off	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		23-24	IP	R/W	unsigned int		default 192.168.0.60	
		25-26	Mask	R/W	unsigned int		default 255.255.255.0	
		36-37	Gateway	R/W	unsigned int		default 192.168.0.1	
		38	BACnet ID	R/W	unsigned int	0 - 4194303	default 60	
		44	Bacnet Port	R/W	unsigned short	1-65535	default 47808	
Main control	Settings	27	Language	R/W	unsigned char	0-255	English = 0, Lithuanian = 1, Russian = 2, ...	
		28	Flow units	R/W	unsigned char	0 - 1	m3/h = 0, l/s = 1	
		42	Fire alarm restart	R/W	unsigned char	0 - 1	Manual = 0, Auto = 1	
		29	Time, HH:MM	R/W	unsigned short	MSB 0x00 - 0x17, LSB 0x00 - 0x3B	MSB - hours, LSB - minutes	0x0B36 => 11:54
		30	Year	R/W	unsigned short	2017 - 2035	Year	0x07E0 => 2016
		31	Month/Day	R/W	unsigned short	MSB 0x01 - 0x0C, LSB 0x01 - 0x1F	MSB - month, LSB - day	0x020C => Feb12
Mode settings	Time and date	32	Week day	RO	unsigned char	1 - 7	Mo = 1, Tu = 2, We = 3, Th = 4, Fr = 5, Sa = 6, Su = 7	
		33-34	Time since 1970	RO	unsigned int	1483228800 - 205122400	based on seconds since stand- ard epoch of 1/1/1970	1456329600 => 2016.02.24 16:00:00
		100-101	Supply flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
		102-103	Extract flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
		104	Setpoint	R/W	signed short	50 - 400	x10 C	
		105	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
Mode settings	Normal	106-107	Supply flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
		108-109	Extract flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
		110	Setpoint	R/W	signed short	50 - 400	x10 C	
		111	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		112-113	Supply flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
		114-115	Extract flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
Mode settings	Intensive	116	Setpoint	R/W	signed short	50 - 400	x10 C	
		117	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Node settings	Boost	118-119	Supply flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
		120-121	Extract flow	R/W	unsigned int	0 - 200000	m3/h, l/s, Pa, %	
		122	Setpoint	R/W	signed short	50 - 400	x10 C	
		123	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
	Kitchen	124-125	Supply flow	R/W	unsigned int	0 - 200000	m3/h, l/s, %	
		126-127	Extract flow	R/W	unsigned int	0 - 200000	m3/h, l/s, %	
		128	Setpoint	R/W	signed short	50 - 400	x10 C	
		129	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		130	Timer time	R/W	unsigned short	0 - 300	Minutes	
	Fireplace	131-132	Supply flow	R/W	unsigned int	0 - 200000	m3/h, l/s, %	
		133-134	Extract flow	R/W	unsigned int	0 - 200000	m3/h, l/s, %	
		135	Setpoint	R/W	signed short	50 - 400	x10 C	
		136	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		137	Timer time	R/W	unsigned short	0 - 300	Minutes	
	Override	138-139	Supply flow	R/W	unsigned int	0 - 200000	m3/h, l/s, %	
		140-141	Extract flow	R/W	unsigned int	0 - 200000	m3/h, l/s, %	
		142	Setpoint	R/W	signed short	50 - 400	x10 C	
		143	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		144	Mode	R/W	unsigned char	0 - 2	All time = 0, If on = 1, If off = 2	
		145	Timer time	R/W	unsigned short	0 - 300	Minutes	
		157	Delayed start	R/W	unsigned char	0 - 10	Minutes	
		158	Delayed stop	R/W	unsigned char	0 - 30	Minutes	
Holidays		146	Microventilation	R/W	unsigned char	1 - 4	Once per day = 1, Twice per day = 2, Thrice per day = 3, Four times per day = 4,	
		147	Setpoint	R/W	signed short	50 - 400	x10 C	
		148	Heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		149-150	From Day/Month	R/W	unsigned int	1483228800 - 2051222400	based on seconds since standard epoch of 1/1/1970	1456329600 => 2016.02.24 16:00:00
		151-152	Till Day/Month	R/W	unsigned int	1483228800 - 2051222400	based on seconds since standard epoch of 1/1/1970	1456329600 => 2016.02.24 16:00:00
		153	Year, from	R/W	unsigned short	2017 - 2035		
		154	Month/Day, from	R/W	unsigned short	MSB 0x01 - 0x0C, LSB 0x01 - 0x1F	MSB = month, LSB = day	0x020C => Feb12
		155	Year, till	R/W	unsigned short	2017 - 2035		
	Eco	156	Month/Day, till	R/W	unsigned short	MSB 0x01 - 0x0C, LSB 0x01 - 0x1F	MSB = month, LSB = day	0x020C => Feb12
		200	Minimum supply air temperature	R/W	unsigned short	50 - 400	x10 C	
		201	Maximum supply air temperature	R/W	unsigned short	50 - 400	x10 C	
		202	Free heating/cooling	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		203	Heating enable denied	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		204	Cooling enable denied	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		217	Heat recovery control	R/W	unsigned char	0 - 2	Auto = 0, Constant = 1, Non stop = 2	

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Air quality	Air quality	205	Air quality Enable	R/W	unsigned char	0 - 1	Disabled = 0, Enabled = 1	
		206	Temperature setpoint	R/W	signed short	50 - 400	x10 C	
		207	Air quality setpoint	R/W	unsigned short	CO2: 0 - 2000, VOC: 0 - 100,	ppm, %	
		208	Humidity setpoint	R/W	unsigned short	RH: 0 - 100,	%	
		209	Air quality minimum intensivity	R/W	unsigned char	0, 20 - 100	%	
		210	Air quality maximum intensivity	R/W	unsigned char	0, 20 - 100	%	
		211	Air quality heating	R/W	unsigned char	0 - 1	Off = 0, On = 1	
		212	Air quality check period	R/W	unsigned char	1 - 24	Hours	
		213	Air quality sensor type B8	R/W	unsigned char	0 - 3	None = 0, CO2 = 1, VOC = 2, RH = 3	
		214	Air quality sensor type B9	R/W	unsigned char	0 - 3	None = 0, CO2 = 1, VOC = 2, RH = 3	
Scheduler	Stay at home	Operation program 1	Weekday mask	Event 1	R/W	unsigned char	0b00000000 - 0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
			Event 2	301	Mode	R/W	unsigned char	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			Event 3	302	Start time	R/W	unsigned short	0:00 - 23:59
			Event 4	303	Stop time	R/W	unsigned short	MSB - hours, LSB - minutes
			Event 5	304	Mode	R/W	unsigned char	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			Event 3	305	Start time	R/W	unsigned short	0:00 - 23:59
			Event 4	306	Stop time	R/W	unsigned short	MSB - hours, LSB - minutes
			Event 5	307	Mode	R/W	unsigned char	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			Event 3	308	Start time	R/W	unsigned short	0:00 - 23:59
			Event 4	309	Stop time	R/W	unsigned short	MSB - hours, LSB - minutes
			Event 5	310	Mode	R/W	unsigned char	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			Event 3	311	Start time	R/W	unsigned short	0:00 - 23:59
			Event 4	312	Stop time	R/W	unsigned short	MSB - hours, LSB - minutes
			Event 5	313	Mode	R/W	unsigned char	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			Event 3	314	Start time	R/W	unsigned short	0:00 - 23:59
			Event 4	315	Stop time	R/W	unsigned short	MSB - hours, LSB - minutes

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Stay at home	Operation program 1	316	Weekday mask	R/W	unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
			317	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			318	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			319	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Operation program 2	320	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			321	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			322	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			323	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
	Operation program 3	Event 1	324	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			325	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			326	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			327	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Event 2	328	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			329	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			330	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			331	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Event 3	332	Weekday mask	R/W	unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
			333	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			334	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			335	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Event 4	336	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			337	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			338	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Stay at home			Operation program 3				
				339	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				340	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				341	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				342	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				343	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				344	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				345	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				346	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				347	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				348	Weekday mask	R/W unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
				349	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				350	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				351	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				352	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				353	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				354	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				355	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				356	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				357	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				358	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				359	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				360	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				361	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4
				362	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				363	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Working week	Weekday mask	Operation program 1	364	Weekday mask	R/W	unsigned char	0b00000000 - 0b01111111 Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
				365	Mode	R/W	unsigned char	0 - 4 Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				366	Start time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				367	Stop time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				368	Mode	R/W	unsigned char	0 - 4 Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				369	Start time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				370	Stop time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				371	Mode	R/W	unsigned char	0 - 4 Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				372	Start time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				373	Stop time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
	Operation program 2	Weekday mask	Event 1	374	Mode	R/W	unsigned char	0 - 4 Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				375	Start time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				376	Stop time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				377	Mode	R/W	unsigned char	0 - 4 Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				378	Start time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				379	Stop time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				380	Weekday mask	R/W	unsigned char	0b00000000 - 0b01111111 Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
				381	Mode	R/W	unsigned char	0 - 4 Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				382	Start time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				383	Stop time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				384	Mode	R/W	unsigned char	0 - 4 Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				385	Start time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes
				386	Stop time	R/W	unsigned short	0:00 - 23:59 MSB - hours, LSB - minutes

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Working week	Operation program 2	387	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			388	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			389	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			390	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			391	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			392	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			393	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			394	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			395	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			396	Weekday mask	R/W	unsigned char	0b00000000- 0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
	Operation program 3	Event 1	397	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			398	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			399	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			400	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			401	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			402	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Event 2	403	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			404	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			405	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			406	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			407	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Event 3	408	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			409	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			410	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			411	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Working week		Operation program 4					
Office	Operation program 1		Weekday mask					

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments	
				Access	Type	Range			
Scheduler	Office						Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4		
				435	Mode	R/W unsigned char	0 - 4		
				436	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				437	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				438	Mode	R/W unsigned char	0 - 4		
				439	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				440	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				441	Mode	R/W unsigned char	0 - 4		
				442	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				443	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				444	Weekday mask	R/W unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit	
				445	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
				446	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				447	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				448	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
				449	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				450	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				451	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
				452	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				453	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				454	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
				455	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				456	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				457	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
				458	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
				459	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Office	Operation program 3	Weekday mask	460	Weekday mask	R/W unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
				461	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				462	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				463	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				464	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				465	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				466	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				467	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
	Operation program 4	Event 1	Weekday mask	468	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				469	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				470	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				471	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				472	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				473	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				474	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				475	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Event 2	Weekday mask	476	Weekday mask	R/W unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
				477	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				478	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				479	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				480	Mode	R/W unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
				481	Start time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
				482	Stop time	R/W unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Custom	Operation program 4	483	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			484	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			485	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			486	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			487	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			488	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			489	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
	Operation program 1	Event 5	490	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			491	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			492	Weekday mask	R/W	unsigned char	0b00000000 - 0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
			493	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			494	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			495	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			496	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
		Event 1	497	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			498	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			499	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			500	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			501	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
	Event 4	Event 2	502	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			503	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			504	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
			505	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal = 2, Intensive = 3, Boost = 4
			506	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes
		Event 5	507	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments			
				Access	Type	Range					
Scheduler	Custom	Operation program 2	Event 1	Weekday/mask	508	Weekday mask	R/W	unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit	
					509	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
					510	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					511	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					512	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
		Operation program 3	Event 2	Weekday/mask	513	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					514	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					515	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
					516	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					517	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
	Custom	Operation program 2	Event 3	Weekday/mask	518	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
					519	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					520	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					521	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
					522	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
	Custom	Operation program 3	Event 4	Weekday/mask	523	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					524	Weekday mask	R/W	unsigned char	0b00000000-0b01111111	Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit	
					525	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
					526	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					527	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
	Custom	Operation program 2	Event 5	Weekday/mask	528	Mode	R/W	unsigned char	0 - 4	Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
					529	Start time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05
					530	Stop time	R/W	unsigned short	0:00 - 23:59	MSB - hours, LSB - minutes	0x0805 => 8:05

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Scheduler	Custom						Standby = 0, Away = 1, Normal =2, Intensive =3, Boost = 4	
								531 Mode R/W unsigned char 0 - 4
								532 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								533 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								534 Mode R/W unsigned char 0 - 4
								535 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								536 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								537 Mode R/W unsigned char 0 - 4
								538 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								539 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								540 Weekday mask R/W unsigned char 0b00000000-0b01111111 Mo => 0 bit, Tu => 1 bit, We => 2 bit, Th => 3 bit, Fr => 4 bit, Sa => 5 bit, Su => 6 bit
								541 Mode R/W unsigned char 0 - 4
								542 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								543 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								544 Mode R/W unsigned char 0 - 4
								545 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								546 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								547 Mode R/W unsigned char 0 - 4
								548 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								549 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								550 Mode R/W unsigned char 0 - 4
								551 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								552 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								553 Mode R/W unsigned char 0 - 4
								554 Start time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05
								555 Stop time R/W unsigned short 0:00 - 23:59 MSB - hours, LSB - minutes 0x0805 => 8:05

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Active alarms	600	Active alarms count	R/W	unsigned char	0 - 10		Writing 0x99C6 - Active alarms reset and restore previous mode
		601	Active alarm 1 code (newest)	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		602	Active alarm 2 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		603	Active alarm 3 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		604	Active alarm 4 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		605	Active alarm 5 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		606	Active alarm 6 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		607	Active alarm 7 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		608	Active alarm 8 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		609	Active alarm 9 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
Alarms	Alarm history	610	Active alarm 10 code	RO	unsigned char	0x01 - 0xFF		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		611	Alarm history count	RO	unsigned char	0 - 50		
		612	Alarm (newest) year	RO	unsigned short	2016 - 2250	Year	
		613	Alarm (newest) month-day	RO	unsigned short	01.01 - 12.31	Month and day	0x020C => Feb12
		614	Alarm (newest) time	RO	unsigned short	0:00 - 23:59	Hours and minutes	0x0805 => 8:05
		615	Alarm (newest) seconds	RO	unsigned char	0 - 59	Seconds	
		616	Alarm (newest) code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
	Alarm 2	617	Alarm year	RO	unsigned short	2016 - 2250	Year	
		618	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day	0x020C => Feb12
		619	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes	0x0805 => 8:05
		620	Alarm seconds	RO	unsigned char	0 - 59	Seconds	
		621	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms		0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Alarms history	Alarm 3	622	Alarm year	RO	unsigned short	2016 - 2250	Year
			623	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			624	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			625	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			626	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
		Alarm 4	627	Alarm year	RO	unsigned short	2016 - 2250	Year
			628	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			629	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			630	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 5	631	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			632	Alarm year	RO	unsigned short	2016 - 2250	Year
			633	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			634	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			635	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 6	636	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			637	Alarm year	RO	unsigned short	2016 - 2250	Year
			638	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			639	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			640	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 7	641	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			642	Alarm year	RO	unsigned short	2016 - 2250	Year
			643	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			644	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			645	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 8	646	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			647	Alarm year	RO	unsigned short	2016 - 2250	Year
			648	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			649	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			650	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 9	651	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSb = 1)
			652	Alarm year	RO	unsigned short	2016 - 2250	Year
			653	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			654	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			655	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			656	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Alarms history	Alarm 10	657	Alarm year	RO	unsigned short	2016 - 2250	Year
			658	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			659	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			660	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			661	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 11	662	Alarm year	RO	unsigned short	2016 - 2250	Year
			663	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			664	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			665	Alarm seconds	RO	unsigned char	0 - 59	Seconds
	Alarms history	Alarm 12	666	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
			667	Alarm year	RO	unsigned short	2016 - 2250	Year
			668	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			669	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			670	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 13	671	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
			672	Alarm year	RO	unsigned short	2016 - 2250	Year
			673	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			674	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
	Alarms history	Alarm 14	675	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			676	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
			677	Alarm year	RO	unsigned short	2016 - 2250	Year
			678	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
		Alarm 15	679	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			680	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			681	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
			682	Alarm year	RO	unsigned short	2016 - 2250	Year
	Alarms history	Alarm 16	683	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			684	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			685	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			686	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 16	687	Alarm year	RO	unsigned short	2016 - 2250	Year
			688	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			689	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			690	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			691	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Alarms history	Alarm 17	692	Alarm year	RO	unsigned short	2016 - 2250	Year
			693	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			694	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			695	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			696	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			697	Alarm year	RO	unsigned short	2016 - 2250	Year
		Alarm 18	698	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			699	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			700	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			701	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			702	Alarm year	RO	unsigned short	2016 - 2250	Year
			703	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
	Alarms	Alarm 19	704	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			705	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			706	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			707	Alarm year	RO	unsigned short	2016 - 2250	Year
			708	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			709	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
		Alarm 20	710	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			711	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			712	Alarm year	RO	unsigned short	2016 - 2250	Year
			713	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			714	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			715	Alarm seconds	RO	unsigned char	0 - 59	Seconds
	Alarms	Alarm 21	716	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			717	Alarm year	RO	unsigned short	2016 - 2250	Year
			718	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			719	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			720	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			721	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
		Alarm 22	722	Alarm year	RO	unsigned short	2016 - 2250	Year
			723	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			724	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			725	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			726	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSb = 1)

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Alarms history	Alarm 24	727	Alarm year	RO	unsigned short	2016 - 2250	Year
			728	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			729	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			730	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			731	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 25	732	Alarm year	RO	unsigned short	2016 - 2250	Year
			733	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			734	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			735	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			736	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 26	737	Alarm year	RO	unsigned short	2016 - 2250	Year
			738	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			739	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			740	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			741	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 27	742	Alarm year	RO	unsigned short	2016 - 2250	Year
			743	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			744	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			745	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			746	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 28	747	Alarm year	RO	unsigned short	2016 - 2250	Year
			748	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			749	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			750	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			751	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 29	752	Alarm year	RO	unsigned short	2016 - 2250	Year
			753	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			754	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			755	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			756	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)
		Alarm 30	757	Alarm year	RO	unsigned short	2016 - 2250	Year
			758	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			759	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			760	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			761	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Alarms history	Alarm 31	762	Alarm year	RO	unsigned short	2016 - 2250	Year
			763	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			764	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			765	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			766	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			767	Alarm year	RO	unsigned short	2016 - 2250	Year
			768	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
		Alarm 32	769	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			770	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			771	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			772	Alarm year	RO	unsigned short	2016 - 2250	Year
			773	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			774	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			775	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 33	776	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			777	Alarm year	RO	unsigned short	2016 - 2250	Year
			778	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			779	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			780	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			781	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			782	Alarm year	RO	unsigned short	2016 - 2250	Year
		Alarm 34	783	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			784	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			785	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			786	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			787	Alarm year	RO	unsigned short	2016 - 2250	Year
			788	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			789	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
		Alarm 35	790	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			791	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			792	Alarm year	RO	unsigned short	2016 - 2250	Year
			793	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			794	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			795	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			796	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSb = 1)
		Alarm 36						
		Alarm 37						

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Alarms history	Alarm 38	797	Alarm year	RO	unsigned short	2016 - 2250	Year
			798	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			799	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			800	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 39	801	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			802	Alarm year	RO	unsigned short	2016 - 2250	Year
			803	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			804	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
	Alarms 40	Alarm 40	805	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			806	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			807	Alarm year	RO	unsigned short	2016 - 2250	Year
			808	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
		Alarm 41	809	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			810	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			811	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			812	Alarm year	RO	unsigned short	2016 - 2250	Year
	Alarms 42	Alarm 42	813	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			814	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			815	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			816	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
		Alarm 43	817	Alarm year	RO	unsigned short	2016 - 2250	Year
			818	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			819	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			820	Alarm seconds	RO	unsigned char	0 - 59	Seconds
	Alarms 44	Alarm 44	821	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			822	Alarm year	RO	unsigned short	2016 - 2250	Year
			823	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			824	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
		Alarm 44	825	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			826	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSb = 1)
			827	Alarm year	RO	unsigned short	2016 - 2250	Year
			828	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			829	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			830	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			831	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSb = 0), 0x82 => 2W (MSb = 1)

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Alarms	Alarms history	Alarm 45	832	Alarm year	RO	unsigned short	2016 - 2250	Year
			833	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			834	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			835	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		Alarm 46	836	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			837	Alarm year	RO	unsigned short	2016 - 2250	Year
			838	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			839	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
		Alarm 47	840	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			841	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			842	Alarm year	RO	unsigned short	2016 - 2250	Year
			843	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
		Alarm 48	844	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			845	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			846	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			847	Alarm year	RO	unsigned short	2016 - 2250	Year
		Alarm 49	848	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			849	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			850	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			851	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
Monitoring	Detailed information	Alarm 50	852	Alarm year	RO	unsigned short	2016 - 2250	Year
			853	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			854	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			855	Alarm seconds	RO	unsigned char	0 - 59	Seconds
		900	856	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSB = 1)
			857	Alarm year	RO	unsigned short	2016 - 2250	Year
			858	Alarm month-day	RO	unsigned short	01.01 - 12.31	Month and day
			859	Alarm time	RO	unsigned short	0:00 - 23:59	Hours and minutes
			860	Alarm seconds	RO	unsigned char	0 - 59	Seconds
			861	Alarm code	RO	unsigned char	1 - 127 F alarms, 129 - 255 W alarms	0x02 => 2F (MSB = 0), 0x82 => 2W (MSb = 1)
			900	Status icon bit mask	RO	unsigned short	0 - 8191	Starting => 0 bit, Stoping => 1 bit, Fan => 2 bit, Rotor => 3 bit, Heating => 4 bit, Cooling => 5 bit, HeatingDenied => 6 bit, CoolingDenied => 7 bit, FlowDown => 8 bit, FreeHeating => 9 bit, FreeCooling => 10 bit, AlarmF => 11 bit, AlarmW => 12 bit

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Monitoring	Detailed information	901	Heating/cooling config	RO	unsigned char	0 - 7	Electric heater => 0 bit, Water cooler/heater => 1 bit, DX unit => 2 bit	
		902	Supply temperature	RO	signed short	-500 - 1200	x10 C	
		903	Extract Temperature	RO	signed short	-500 - 1200	x10 C	
		904	Outdoor temp	RO	signed short	-500 - 1200	x10 C	
		905	Water temperature	RO	signed short	-500 - 1200	x10 C	
		906-907	Current supply flow	RO	unsigned int	0 - 200000	m3/h, l/s	
		908-909	Current extract flow	RO	unsigned int	0 - 200000	m3/h, l/s	
		910	Current supply fan intensity	RO	unsigned short	0 - 1000	x10 %	
		911	Current extract fan intensity	RO	unsigned short	0 - 1000	x10 %	
		912	Heat exchanger	RO	unsigned short	0 - 1000	x10 %	
		913	Electric heater	RO	unsigned short	0 - 1000	x10 %	
		914	Water heater	RO	unsigned short	0 - 1000	x10 %	
		915	Water cooler	RO	unsigned short	0 - 1000	x10 %	
		916	DX unit	RO	signed short	-1000 - +1000	x10 %	
		917	Filters Impurity	RO	unsigned char	0 - 100	%	
		918	Air dampers	RO	unsigned char	0 - 100	%	
		919	Supply pressure	RO	unsigned short	0 - 1000	Pa	
		920	Extract pressure	RO	unsigned short	0 - 1000	Pa	
		952	Air quality or humidity (sensor 1 - B8)	RO	unsigned short	0 - 65535	ppm,%	
		953	Air quality or humidity (sensor 2 - B9)	RO	unsigned short	0 - 65535	ppm,%	
		955	Heat exchanger type	RO	unsigned char	0 - 1	Plate = 0, Rotary = 1	
		961	Exhaust temperature	RO	signed short	-500 - 1200	x10 C	
Consumption	Efficiency status	921	Power consumption	RO	unsigned short	0 - 65535	W	
		922	Heater power	RO	unsigned short	0 - 65535	W	
		923	Heat exchanger recovery	RO	unsigned short	0 - 65535	W	
		924	Heat exchanger efficiency	RO	unsigned char	0 - 100	%	
		925	Energy saving	RO	unsigned char	0 - 100	%	
		926	SPI	RO	unsigned short	0 - 65535	W/(m3/h)	
	Consumption	927-928	AHU consumption, Day	RO	unsigned int	0 - 4294967296	Wh	
		929-930	AHU consumption, Month	RO	unsigned int	0 - 4294967296	Wh	
		931-932	AHU consumption, Total	RO	unsigned int	0 - 4294967296	Wh	
		933-934	Add. air heater consumption, Day	RO	unsigned int	0 - 4294967296	Wh	
		935-936	Add. air heater consumption, Month	RO	unsigned int	0 - 4294967296	Wh	
		937-938	Add. air heater consumption, Total	RO	unsigned int	0 - 4294967296	Wh	
		939-940	Recovered energy, Day	RO	unsigned int	0 - 4294967296	Wh	
		941-942	Recovered energy, Month	RO	unsigned int	0 - 4294967296	Wh	
		943-944	Recovered energy, Total	RO	unsigned int	0 - 4294967296	Wh	
		945	SPI per day	RO	unsigned short	0 - 65535	W/(m3/h)	

Group	Subgroups	Register number	Register name	Data			Values and Units	Examples and comments
				Access	Type	Range		
Monitoring	Panel	946	Panel 1 temperature	RO	signed short	-500 - 1200	x10 C	
		947	Panel 1 humidity	RO	signed char	0 - 100	%	
		948	Panel 1 air quality	RO	unsigned short	0 - 65535	ppm, ppb	
		949	Panel 2 temperature	RO	signed short	-500 - 1200	x10 C	
		950	Panel 2 humidity	RO	signed char	0 - 100	%	
		951	Panel 2 air quality	RO	unsigned short	0 - 65535	ppm, ppb	
		954	Connected panels	RO	unsigned char	0 - 3	None = 0, Panel(1) = 1, Panel(2) = 2, Panel(1) and Panel(2) = 3	
Others	DOUT	958	Alarm	RO	unsigned char	0 - 1	Off = 0, On = 1	
		959	Heating	RO	unsigned char	0 - 1	Off = 0, On = 1	
		960	Cooling	RO	unsigned char	0 - 1	Off = 0, On = 1	
		1000-1001	Firmware version	RO	unsigned int	1 - 4294967295	1st number 8bit <<24, 2nd number 4bit <<20, 3rd number 8bit <<12, 4th number 12bit<<0	18886660 => 1.2.3.4
		1002-1003	Panel 1 firmware version	RO	unsigned int	1 - 4294967295	1st number 8bit <<24, 2nd number 4bit <<20, 3rd number 8bit <<12, 4th number 12bit<<0	18886660 => 1.2.3.4
		1004-1005	Panel 2 firmware version	RO	unsigned int	1 - 4294967295	1st number 8bit <<24, 2nd number 4bit <<20, 3rd number 8bit <<12, 4th number 12bit<<0	18886660 => 1.2.3.4
		1050	Reset settings	R/W	unsigned short	0 - 11	Reset Away settings = 1, Reset Normal settings = 2, Reset Intensive settings = 3, Reset Boost settings = 4, Reset Holidays settings = 5, Reset Override settings = 6, Reset Kitchen settings = 7, Reset Fireplace settings = 8, Reset Air quality settings = 9, Reset Eco settings = 10, Reset Advanced settings = 11	
		1051	Clean filters calibration	R/W	unsigned char	1	Confirm = 1	Resets filters counter, if filter clogging is more than 1%

### Alarm codes (registers 600-861)

Code		Text	Message
Hex	Dec		
01	1	F1	Supply Flow Not Reached
02	2	F2	Exhaust Flow Not Reached
03	3	F3	Water Temp B5 To Low
04	4	F4	Low Supply Air Temperature
05	5	F5	High Supply Air Temperature
06	6	F6	Electric Heater Overheat
07	7	F7	Heat Exchanger Failure
08	8	F8	Heat Exchanger Icing
09	9	F9	Internal Fire
0A	10	F10	External Fire
0B	11	F11	Supply Air Temp B1 Short
0C	12	F12	Supply Air Temp B1 Not Connected
0D	13	F13	Extract Air Temp B2 Short
0E	14	F14	Extract Air Temp B2 Not Connected
0F	15	F15	Outdoor Air Temp B3 Short
10	16	F16	Outdoor Air Temp B3 Not Connected

Code		Text	Message
Hex	Dec		
11	17	F17	Exhaust Air Temp B4 Short
12	18	F18	Exhaust Air Temp B4 Not Connected
13	19	F19	Water Temp B5 Short
14	20	F20	Water Temp B5 Not Connected
15	21	F21	Supply Temp After Hx B10 Short
16	22	F22	Supply Temp After Hx B10 Not Connected
17	23	F23	Flash Fail
18	24	F24	Too Low 24V Supply Voltage
19	25	F25	Too High 24V Supply Voltage
1A	26	F26	24V Supply Voltage Overloaded
1C	28	F28	Room Temperature Sensor Fail
1D	29	F29	Room Humidity Sensor Fail
1E	30	F30	Humidity sensor failure
1F	31	F31	Impurity sensor failure
20	32	F32	Heat Exchanger Failure
21	33	F33	Heat Exchanger Failure
22	34	F34	Heat Exchanger Failure
23	35	F35	Heat Exchanger Failure
24	36	F36	Heat Exchanger Failure
25	37	F37	Heat Exchanger Failure
26	38	F38	Air flow sensor failure
27	39	F39	Air flow sensor failure
28	40	F40	Communication error
29	41	F41	Fire dampers failure
2A	42	F42	Fire damper failure
2B	43	F43	Fire damper failure
2C	44	F44	Fire damper failure
2D	45	F45	Fire damper failure
2E	46	F46	External fire alarm
2F	47	F47	External fire alarm
30	48	F48	External fire alarm
31	49	F49	External fire alarm
32	50	F50	External fire alarm
33	51	F51	Electric heater failure
34	52	F52	Electric preheater failure
81	129	W1	Change Air Filter
82	130	W2	Service Mode
83	131	W3	Water Temp B5 To Low (Warning)
84	132	W4	Humidity sensor failure
85	133	W5	Impurity sensor failure
86	134	W6	Low heat exchanger efficiency

**SERVICE AND SUPPORT**

**LITHUANIA**  
**UAB KOMFOVENT**  
Phone: +370 5 200 8000  
service@komfovent.com  
www.komfovent.com

**FINLAND**  
**Komfovent Oy**  
Muuntotie 1 C1  
FI-01 510 Vantaa, Finland  
Phone: +358 20 730 6190  
toimisto@komfovent.com  
www.komfovent.com

**GERMANY**  
**Komfovent GmbH**  
Konrad-Zuse-Str. 2a,  
42551 Velbert, Deutschland  
Phone: +49 0 2051 6051180  
info@komfovent.de  
www.komfovent.de

**LATVIA**  
**SIA Komfovent**  
Bukaišu iela 1, LV-1004 Riga, Latvia  
Phone: +371 24 66 4433  
info.lv@komfovent.com  
www.komfovent.com

**SWEDEN**  
**Komfovent AB**  
Ögårdesvägen 12A  
433 30 Partille, Sverige  
Phone: +46 31 487 752  
info\_se@komfovent.com  
www.komfovent.se

**UNITED KINGDOM**  
**Komfovent Ltd**  
Unit C1 The Waterfront  
Newburn Riverside  
Newcastle upon Tyne NE15 8NZ, UK  
Phone: +447983 299 165  
steve.mulholland@komfovent.com  
www.komfovent.com

**PARTNERS**

<b>AT</b>	J. PICHLER Gesellschaft m. b. H.	<a href="http://www.pichlerluft.at">www.pichlerluft.at</a>
<b>BE</b>	Ventilair group ACB Airconditioning	<a href="http://www.ventilairgroup.com">www.ventilairgroup.com</a> <a href="http://www.acbairco.be">www.acbairco.be</a>
<b>CZ</b>	REKUVENT s.r.o.	<a href="http://www.rekuvent.cz">www.rekuvent.cz</a>
<b>CH</b>	WESCO AG SUDCLIMATAIR SA CLIMAIR GmbH	<a href="http://www.wesco.ch">www.wesco.ch</a> <a href="http://www.sudclimatair.ch">www.sudclimatair.ch</a> <a href="http://www.climair.ch">www.climair.ch</a>
<b>DK</b>	Øland A/S	<a href="http://www.oeland.dk">www.oeland.dk</a>
<b>EE</b>	BVT Partners	<a href="http://www.bvtpartners.ee">www.bvtpartners.ee</a>
<b>FR</b>	ATIB	<a href="http://www.atib.fr">www.atib.fr</a>
<b>HR</b>	Microclima	<a href="http://www.microclima.hr">www.microclima.hr</a>
<b>HU</b>	AIRVENT Légtechnikai Zrt. Gevent Magyarország Kft. Merkapt	<a href="http://www.airvent.hu">www.airvent.hu</a> <a href="http://www.gevent.hu">www.gevent.hu</a> <a href="http://www.merkapt.hu">www.merkapt.hu</a>
<b>IE</b>	Lindab	<a href="http://www.lindab.ie">www.lindab.ie</a>
<b>IR</b>	Fantech Ventilation Ltd	<a href="http://www.fantech.ie">www.fantech.ie</a>
<b>IS</b>	Blikk & Tækniþjónustan ehf Hitataekni ehf	<a href="http://www.bogt.is">www.bogt.is</a> <a href="http://www.hitataekni.is">www.hitataekni.is</a>
<b>IT</b>	ICARIA	<a href="http://www.icaria.srl">www.icaria.srl</a>
<b>NL</b>	Ventilair group DECIPOL-Vortvent CLIMA DIRECT BV	<a href="http://www.ventilairgroup.com">www.ventilairgroup.com</a> <a href="http://www.vortvent.nl">www.vortvent.nl</a> <a href="http://www.climadirect.com">www.climadirect.com</a>
<b>NO</b>	Ventilution AS Ventistål AS Thermo Control AS	<a href="http://www.ventilution.no">www.ventilution.no</a> <a href="http://www.ventistal.no">www.ventistal.no</a> <a href="http://www.thermocontrol.no">www.thermocontrol.no</a>
<b>PL</b>	Ventia Sp. z o.o.	<a href="http://www.ventia.pl">www.ventia.pl</a>
<b>SE</b>	Nordisk Ventilator AB	<a href="http://www.nordiskventilator.se">www.nordiskventilator.se</a>
<b>SI</b>	Agregat d.o.o.	<a href="http://www.agregat.si">www.agregat.si</a>
<b>SK</b>	TZB produkt, s.r.o.	<a href="http://www.tzbprodukt.sk">www.tzbprodukt.sk</a>
<b>UA</b>	TD VECON LLC	<a href="http://www.vecon.ua">www.vecon.ua</a>